



**NOTES:**

1. IN ROADWAYS USE 17 x 30 TRAFFIC RATED BOX MARKED "SEWER". IN NON TRAVELED APPLICATIONS, USE CARSON 1730 METER BOX, GREEN IN COLOR, MARKED "SEWER".
2. SDRSD WV-02 SHALL TAKE PRECEDENCE FOR THE COVER IN THE PAVEMENT.
3. SIZE SHALL BE 4" OR MATCH FM/LPS, WHICH EVER IS SMALLER.
4. HDPE PIPE 4" AND LARGER, USE HDPE FLANGE ADAPTERS, WHERE FLANGE CONNECTIONS OCCUR. ALL FLANGE ADAPTERS SHALL BE STAINLESS STEEL.
5. HDPE PIPE 3" AND SMALLER, USE HDPE THREADED UNIONS IN PLACE OF FLANGES.

<p>APPROVED:</p> <p><i>Wally P. [Signature]</i> 5/16/19</p> <p>District Engineer                      Date</p> <p>5/16/2019</p> <p>Latest Revision Date</p>	<p style="text-align: center;">  <b>VALLEY CENTER MUNICIPAL WATER DISTRICT</b>  <b>STANDARD DRAWING</b> </p> <p style="text-align: center;"><b>LOW PRESSURE BLOWOFF</b></p>	<p>NOT TO SCALE</p> <p>DWG. NUMBER</p> <p style="font-size: 24pt;"><b>LPS-8</b></p>
---	--	---