



SEE DRAWING S-11
FOR CONTINUATION
OF SEWER LATERAL
TO PROPERTY LINE

THE VERTICAL PIPE
SHALL BE BRACED
WHILE BACKFILLING
TRENCH

NOTE:
ALL JOINTS ON SEWER LATERAL PIPE
SHALL BE COMPRESSION TYPE OR
APPROVED SOLVENT WELD

Ⓢ
LEGEND ON PLAN

APPROVED:
Wally A. ... 3/2/2020
District Engineer Date
3/2/2020
Latest Revision Date

 VALLEY CENTER MUNICIPAL WATER DISTRICT
STANDARD DRAWING

**DEEP CUT
SEWER LATERAL**

NOT TO SCALE
DWG. NUMBER
S-12