



NOTES:

1. CLEANOUTS TO BE INSTALLED AT THE END OF MAINS WHERE INDICATED ON THE PLANS.
2. CLEANOUT PIPE TO BE SAME MATERIAL AND SIZE AS SEWER MAIN.
3. BACKFILL TO TOP OF 45° BEND WITH 3/4" CRUSHED ROCK.

— (CO)
LEGEND ON PLAN

NO.	DESCRIPTION	NO.	DESCRIPTION
1	SBF 1257 CLEANOUT BOX COVER MARKED "VCMWD SEWER"	5	SE 30 SAND PIPE BEDDING
2	CONCRETE RING, 3250 PSI	6	SEWER MAIN
3	SIZE x REQUIRED LENGTH PVC PIPE	7	3/4" CRUSHED ROCK (SEE NOTE 3)
4	45° ELBOW	8	14" DIA. SCH 40 RISER PIPE, WITH REDWOOD BLOCKS

<p>APPROVED:</p> <p><i>Dolly G...</i> 11-20-2021</p> <p>District Engineer Date</p> <p>10/20/2021</p> <p>Latest Revision Date</p>	<p>VALLEY CENTER MUNICIPAL WATER DISTRICT STANDARD DRAWING</p>	<p>NOT TO SCALE</p> <p>DWG. NUMBER</p> <p>S-14</p>
SEWER CLEANOUT		