



NOTES:

1. REFER TO STANDARD DRAWINGS OF MANHOLES FOR DETAILS PERTAINING TO MANHOLES ONLY.
2. THE TOP 1/2 DIAMETER OF THE PIPE IS TO BE BROKEN OUT TO A NEAT LINE. BROKEN EDGES SHALL BE PLASTERED SMOOTH WITH CEMENT MORTAR.
3. THE MAXIMUM NUMBER OF LATERALS INTO A TERMINUS MANHOLE SHALL BE LIMITED TO FOUR.
4. TERMINUS MANHOLES WITH HOUSE LATERALS ARE NOT TO BE USED EXCEPT WITH SPECIAL WRITTEN APPROVAL BY DISTRICT ENGINEER.

○ ————
LEGEND ON PLAN

<p>APPROVED:</p> <p><i>Wally A. H.</i> 3/2/2020</p> <p>District Engineer Date</p> <p>3/2/2020</p> <p>Latest Revision Date</p>	<p style="text-align: center;">  VALLEY CENTER MUNICIPAL WATER DISTRICT STANDARD DRAWING </p> <p style="text-align: center;">TERMINUS MANHOLE</p>	<p>NOT TO SCALE</p> <p>DWG. NUMBER</p> <p style="text-align: center;">S-6</p>
--	--	--