



NOTES:

1. REFER TO BACKFILLING SECTION OF THE SPECIFICATIONS FOR DETAILS.
2. PAVING OR PAVEMENT REPAIR TO BE DONE IN ACCORDANCE WITH SDRSD G-24A.
3. EXCAVATE BELL HOLES AT EACH PIPE JOINT TO PERMIT PROPER ASSEMBLY AND INSPECTION OF THE ENTIRE JOINT.
4. ON CITY, COUNTY OR STATE RIGHT OF WAYS, ITS AGENCY STANDARDS SHALL APPLY.

<p>APPROVED:</p> <p><i>Wally A. ...</i> 3/2/2020</p> <p>District Engineer Date</p> <p>3/2/2020</p> <p>Latest Revision Date</p>	<p>VALLEY CENTER MUNICIPAL WATER DISTRICT STANDARD DRAWING</p> <p>STANDARD PIPE ZONE AND TRENCH BACKFILL</p>	<p>NOT TO SCALE</p> <p>DWG. NUMBER</p> <p>S-8</p>
--	---	--