



DISTRICT | PRIVATE

LETTER "W" STAMPED OR CHISELED IN FACE OF CURB NOT LESS THAN 2" HIGH & 3/16" DEEP

UNIMPROVED AREA

18" MIN.
WARNING TAPE

SLOPE UPWARD

45° MAX.
30° MIN.

ACP, PVC OR DUCTILE IRON PIPE

STEEL PIPE

CONNECTION TO STEEL PIPE

NOTE:

1. FOR THE LOCATION OF APPURTENANCES SEE STANDARD DRAWING NO. W-2
2. DISTRICT INSTALLED BACKFLOW AREA TO REMAIN CLEAR.

1" LEGEND ON PLANS

NO.	DESCRIPTION
1	MAIN SIZE x SERVICE SIZE, BRONZE DOUBLE STRAP SADDLE FOR ACP & DIP, SS DOUBLE STRAP FOR PVC
2	BRONZE BALL CORPORATION STOP M.I.P. x COMP (OPERATING NUT TO BE POSITIONED ON RIGHT SIDE)
3	COPPER TUBING x REQUIRED LENGTH x SERVICE SIZE, TYPE K SOFT COPPER
4	BRONZE BALL ANGLE METER STOP w/LOCKWING (1" COMP x METER SWIVEL)
5	PLASTIC METER BOX
6	FORGED STEEL HIGH PRESSURE 1/2 COUPLING

APPROVED:

 District Engineer Date
 10/20/2021
 Latest Revision Date

VALLEY CENTER MUNICIPAL WATER DISTRICT
 STANDARD DRAWING
3/4" AND 1" WATER SERVICE

NOT TO SCALE
 DWG. NUMBER
W-3