



**NOTE:**  
FOR LOCATION OF APPURTENANCES  
SEE STANDARD DRAWING NO. W-2.

CONNECTION TO CML&C

CONNECTION TO PVC & AC

4"  
LEGEND ON PLANS

NO.	SIZE & DESCRIPTION	NO.	SIZE & DESCRIPTION
1	4" x 2-1/2" ANGLE FIRE PLUG VALVE	6	4" STEEL FLANGE OUTLET
2	4" COMPANION FLANGE	7	CONCRETE THRUST BLOCK, PER W-20
3	4" CML&C x REQUIRED LENGTH	8	MAIN SIZE x 4" C.I. TEE W/ FLG OUTLET
4	4" FLG. x FLG. 90° BEND	9	VALVE WELL FRAME, ASSEMBLY, AND COVER PER W-25
5	4" RESILIENT SEATED GATE VALVE (FLG. x FLG. OR SEE SPEC.)	10	30" x 30" x 4" CONCRETE PAD

APPROVED:  
  
 District Engineer      Date  
 5/16/2019  
 Latest Revision Date

VALLEY CENTER MUNICIPAL WATER DISTRICT  
 STANDARD DRAWING  
**4" BLOW OFF ASSEMBLY**

NOT TO SCALE  
 DWG. NUMBER  
**W-11**