



NOTES:
 A. FOR THE LOCATION OF APPURTENANCES SEE STANDARD DRAWING NO. W-2.
 B. SIZE OF VALVES, PIPING, FITTINGS AND OUTLETS 3" OR 4" AS NOTED ON PLANS.

NO.	DESCRIPTION	NO.	DESCRIPTION
1	90° ELL, FLANGED, STEEL CML&C OR CAST IRON CEMENT LINED	7	30" x 30" x 4" CONCRETE PAD
2	STEEL OR DUCTILE IRON PIPE, 12GA. MINIMUM	8	ENCLOSURE, SEE DWG. W-16
3	RESILIENT WEDGE GATE VALVE, FLANGED CLASS TO MATCH PIPE	9	TRACER WIRE
4	AIR & VACUUM RELIEF VALVE	10	3 1/2" OR 4 1/2" I.D. PVC SLEEVE
5	90° STREET ELLS, REQ'D. SIZE W/ SS BUG SCREEN	11	MAIN SIZE x 3" OR 4" C.I. TEE W/ FLG OUTLET
6	VALVE WELL FRAME, ASSEMBLY, AND COVER PER W-25		

APPROVED:
Wally P. ... 5/16/19
 District Engineer Date
 5/16/2019
 Latest Revision Date

VALLEY CENTER MUNICIPAL WATER DISTRICT
 STANDARD DRAWING
**3" OR 4" COMBINATION AIR VALVE
 OR AIR & VACUUM VALVE ASSEMBLIES**

NOT TO SCALE
 DWG. NUMBER
W-15