



NOTES:

1. REFER TO BACKFILLING SECTION OF THE SPECIFICATIONS FOR DETAILS.
2. PAVING OR PAVEMENT REPAIR TO BE DONE IN ACCORDANCE WITH SDRSD DETAIL G-24A.
3. EXCAVATE BELL HOLES AT EACH PIPE JOINT TO PERMIT PROPER ASSEMBLY AND INSPECTION OF THE ENTIRE JOINT.
4. ON CITY, COUNTY OR STATE RIGHT OF WAYS, ITS AGENCY STANDARDS SHALL APPLY.

APPROVED:
Wally P. [Signature] 5/16/19
 District Engineer Date
 5/16/2019
 Latest Revision Date



VALLEY CENTER MUNICIPAL WATER DISTRICT
 STANDARD DRAWING

**STANDARD PIPE ZONE
 AND TRENCH BACKFILL**

NOT TO SCALE

DWG. NUMBER

W-17