

**VALVE WELL AND FRAME
FOR NEW INSTALLATION**


NOTES:

1. PROVIDE VALVE KEY EXTENSION WHERE THIS DIMENSION EXCEEDS 72".
2. THE SURFACE OF THE VALVE WELL COVER SHALL MATCH THE STREET CROSS SLOPE AND PROFILE.
3. SEE STANDARD DRAWING W-23 AND W-24 FOR VALVE WELL EXTENSION WHEN REQUIRED.
4. RAISE VALVE LID(S) TO FINISHED SURFACE AFTER FINAL PAVING IS COMPLETE.
5. LID TO SAY "VCMWD SEWER" IF USED FOR LPS-7.

VALVE CAN LID PAINT COLORS

MAIN LINE VALVES	B.O.'s & F.H.'s	A.V.	FIRE SERVICE VALVES	BYPASS VALVES	MANIFOLD ASSEMBLY
RED	YELLOW	WHITE	BLUE	BLUE	BLUE

CLOSED VALVES = PAINTED "X"

APPROVED:

 District Engineer Date
 3/2/2020
 Latest Revision Date



VALLEY CENTER MUNICIPAL WATER DISTRICT
STANDARD DRAWING

**VALVE WELL CAP
AND CAN INSTALLATION**

NOT TO SCALE

DWG. NUMBER

W-25