



ELEVATION

NOTES:

1. CONTRACTOR TO VERIFY ALL DIMENSIONS PRIOR TO PURCHASE AND FABRICATION.
2. PAINT PER DISTRICT SPECIFICATIONS AFTER FABRICATION.

NO.	DESCRIPTION	NO.	DESCRIPTION
1	2 1/2" GALVANIZED STEEL PIPE	6	SADDLE TYPE PIPE SUPPORT
2	ADJUSTABLE THREADED COLLAR, GALVANIZED	7	STAINLESS STEEL 316 NUT AND WASHER (4 REQUIRED)
3	3" GALVANIZED STEEL PIPE, WELDED TO BASE	8	STAINLESS STEEL 316 LEVELING NUT AND WASHER (4 REQUIRED)
4	9" x 9" x 1/2" GALVANIZED STEEL BASE PLATE w/4 BOLT HOLES	9	1" THICK MIN. NON-SHRINK GROUT
5	1/4" THICK NEOPRENE LINER	10	1/2" DIA. STAINLESS STEEL 316 ANCHOR BOLT (4 REQUIRED)

APPROVED: District Engineer Date 5/16/2019 Latest Revision Date	VALLEY CENTER MUNICIPAL WATER DISTRICT STANDARD DRAWING	NOT TO SCALE DWG. NUMBER <b style="font-size: 1.5em;">W-34
ADJUSTABLE PIPE SUPPORT DETAIL		