



NO.	DESCRIPTION	NO.	DESCRIPTION
1	TRACER WIRE, MECHANICALLY BONDED TO CORP. STOP	6	1" BRONZE BALL CORP. STOP M.I.P. x COMP (OPERATING NUT TO BE ON THE RIGHT SIDE)
2	ARMOLITE POLYETHYLENE ENCLOSURE WITH HINGED COVER (W/ GRANITE FINISH)	7	1" BRONZE DOUBLE STRAP SADDLE FOR ACP & DIP, SS DOUBLE STRAP FOR PVC
3	PADLOCK HASP	8	VALVE WELL FRAME, ASSEMBLY, AND COVER, PER W-25
4	BALL VALVE, 1/2" x 3/8", 400 P.S.I.	9	1" COPPER TUBING x REQ. LENGTH
5	1" BRONZE GATE VALVE w/BRONZE HANDWHEEL, F.I.P. x F.I.P. THREAD	10	1" COPPER COMP ADAPTER x M.I.P. THREAD

APPROVED:

 District Engineer Date
 5/16/2019
 Latest Revision Date



VALLEY CENTER MUNICIPAL WATER DISTRICT
 STANDARD DRAWING

**WATER QUALITY
 SAMPLING STATION**

NOT TO SCALE

DWG. NUMBER

W-35