



**NOTES:**

1. INSTALL TEST STATION OVER PIPE IF POSSIBLE. OFFSET POST AS NECESSARY TO PLACE IN PROTECTED AREA AND PUT OF TRAFFIC LANES, BUT NOT OUTSIDE RIGHT OF WAY.
2. FOUR-WIRE TEST STATION SHOWN IS APPLICABLE TO CASING AND INSULATING FLANGE TEST STATIONS (SEE W-43 AND W-45). TWO WIRE TEST STATIONS SIMILAR.
3. EACH WIRE SHALL BE IDENTIFIED WITH A DYMO LABEL AFFIXED TO THE MICARTA PANEL. LABEL WILL IDENTIFY VCMWD, SIZE, MAT'L AND SERVICE (I.E. VCMWD, 14", CML&C, W)

APPROVED:  
*Wally P. ...* 5/16/19  
 District Engineer Date  
 5/16/2019  
 Latest Revision Date


 VALLEY CENTER MUNICIPAL WATER DISTRICT  
 STANDARD DRAWING  
**2 OR 4 - WIRE TEST STATION**

NOT TO SCALE  
 DWG. NUMBER  
**W-41**