

BRASS TAG LEGEND


WIRE	SIZE	ID STAMP
A1	NO. 8	"VCMWD, SIZE, MAT'L, SERVICE, SO. OR WT"
A2	SEE NOTE 3	"VCMWD, SIZE, MAT'L, SERVICE, SO. OR WT"
B1	SEE NOTE 3	"VCMWD, SIZE, MAT'L, SERVICE, SO. OR ET"
B2	NO. 8	"VCMWD, SIZE, MAT'L, SERVICE, SO. OR ET"

EXAMPLE: "VCMWD 42" W-ET"

NOTES:

- SEE DWG. W-39 FOR PLACEMENT OF TEST BOX.
- SEE DWG. W-42 FOR MOUNTING AND BRASS ID TAG REQUIREMENTS.
- SECOND WIRE (A2 & B1) ON EACH SIDE OF INSULATOR IS SIZED FOR POSSIBLE FUTURE BOND AS FOLLOWS:

WIRE	PIPE DIA	SIZE
A1 & B1	LESS THAN 12"	NO. 6 AWG HMWPE
	12" TO 18"	NO. 4 AWG HMWPE
	GREATER THAN 18"	NO. 2 AWG HMWPE

APPROVED:

 District Engineer Date
 5/16/2019
 Latest Revision Date



**BURIED INSULATING FLANGE
 AT - GRADE TEST STATION**

NOT TO SCALE
 DWG. NUMBER
W-44