



**NOTES:**

1. 2 BOND WIRES PER JOINT. SEE DWG W-46 FOR WIRE SIZE.
2. CHIP OUT MORTAR ONLY AS NECESSARY TO ALLOW WELD MOLD TO SET FLUSH ON CYLINDER OR BELL.
3. BOND WIRES TO BE AS SHORT AS PRACTICAL BUT NOT LESS THAN 6 INCHES.

<p>APPROVED:</p> <p><i>Wally P. [Signature]</i> 5/16/19</p> <p>District Engineer Date</p> <p>5/16/2019</p> <p>Latest Revision Date</p>	<p>VALLEY CENTER MUNICIPAL WATER DISTRICT STANDARD DRAWING</p> <p><b>CML&amp;C STEEL PIPE JOINT BOND (WIRE JUMPER)</b></p>	<p>NOT TO SCALE</p> <p>DWG. NUMBER</p> <p><b>W-48</b></p>
--	--	---