



NOTES:

1. HORIZONTAL DISTANCES OFF PIPE SHALL BE MAXIMUM WITHIN VCMWD RIGHT-OF-WAY OR AS INDICATED ON PLAN DRAWINGS. DO NOT INSTALL ANODE SUCH THAT A FOREIGN METALLIC PIPELINE EXISTS BETWEEN ANODE AND PIPE.
2. DEPTH IS 12' UNLESS OTHERWISE INDICATED.
3. RELATIVE POSITION OF ANODE, PIPE AND TEST BOX CAN VARY FROM POSITION SHOWN. SEE CP DRAWINGS OR ENGINEER FOR SPECIFIC INSTALLATION REQUIREMENTS.
4. CATHODIC PROTECTION PLAN MUST BE TURNED INTO THE DISTRICT FOR REVIEW AND APPROVAL.

<p>APPROVED: District Engineer Date 5/16/2019 Latest Revision Date</p>	<p style="text-align: center;"> VALLEY CENTER MUNICIPAL WATER DISTRICT STANDARD DRAWING SINGLE ANODE INSTALLATION </p>	<p>NOT TO SCALE DWG. NUMBER W-50</p>
--	--	---